



中国国家强制性产品认证证书

证书编号: 2016011002890090

委托人名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产者(制造商)名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产企业名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园B栋

产品名称和系列、规格、型号

LED模块用交流电子控制装置(LED控制装置, 独立式, 恒压/恒流模式, 安全特低电压, $t_a: 50^{\circ}\text{C}$, $t_c: 90^{\circ}\text{C}$, I类, IP65, F标记, 定温热保护: 110°C)

见附件。100-240V~ 50/60Hz

产品标准和技术要求

GB19510.14-2009, GB19510.1-2009, GB17743-2007, GB17625.1-2012

上述产品符合强制性产品认证实施规则
CNCA-C10-01: 2014的要求, 特发此证。

发证日期: 2016年08月09日 有效期至: 2021年08月09日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1504502



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2016011002890090

NAME AND ADDRESS OF THE APPLICANT

Mean Well (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME AND ADDRESS OF THE MANUFACTURER

Mean Well (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME AND ADDRESS OF THE FACTORY

Mean Well (Guangzhou) Electronics Co., Ltd.
B Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME, MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (Independent,
Constant Voltage/Constant Current Mode, SELV, ta:50°C, tc:90°C, Class
I, IP65, F Mark, Temperature Declared Thermally Protected: 110°C)
See Appendix. 100-240V~ 50/60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB19510.14-2009, GB19510.1-2009, GB17743-2007, GB17625.1-2012

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C10-01:2014).

Date of issue: Aug. 09, 2016 Date of expiry: Aug. 09, 2021

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1504502



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2016011002890090

纸号: 1504502

序号	产品型号	参数	备注
1	ELG-200-12A	输出 (当输入电压: 100-200Vac): 12Vdc, 12A (恒压恒流), 配套光源: 144W LED 模块; 输出 (当输入电压: 200-240Vac): 12Vdc, 16A (恒压恒流), 配套光源: 192W LED 模块	—
2	ELG-200-24A	输出 (当输入电压: 100-200Vac): 24Vdc, 6.25A (恒压恒流), 配套光源: 150W LED 模块; 输出 (当输入电压: 200-240Vac): 24Vdc, 8.4A (恒压恒流), 配套光源: 201.6W LED 模块	—
3	ELG-200-36A	输出 (当输入电压: 100-200Vac): 36Vdc, 4.16A (恒压恒流), 配套光源: 149.76W LED 模块; 输出 (当输入电压: 200-240Vac): 36Vdc, 5.55A (恒压恒流), 配套光源: 199.8W LED 模块	—
4	ELG-200-42A	输出 (当输入电压: 100-200Vac): 42Vdc, 3.57A (恒压恒流), 配套光源: 149.94W LED 模块; 输出 (当输入电压: 200-240Vac): 42Vdc, 4.76A (恒压恒流), 配套光源: 199.9W LED 模块	—
5	ELG-200-48A	输出 (当输入电压: 100-200Vac): 48Vdc, 3.12A (恒压恒流), 配套光源: 149.76W LED 模块; 输出 (当输入电压: 200-240Vac): 48Vdc, 4.16A (恒压恒流), 配套光源: 199.68W LED 模块	—
6	ELG-200-54A	输出 (当输入电压: 100-200Vac): 54Vdc, 2.78A (恒压恒流), 配套光源: 150.12W LED 模块; 输出 (当输入电压: 200-240Vac): 54Vdc, 3.72A (恒压恒流), 配套光源: 200.88W LED 模块	—

注: 此附录与证书同时使用时有效;



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>









中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2016011002890090

纸号: 1504502

7	ELG-240-24A	输出 (当输入电压: 100-200Vac): 24Vdc, 7.5A (恒压恒流), 配套光源: 180W LED 模块; 输出 (当输入电压: 200-240Vac): 24Vdc, 10A (恒压恒流), 配套光源: 240W LED 模块	—
8	ELG-240-36A	输出 (当输入电压: 100-200Vac): 36Vdc, 5A (恒压恒流), 配套光源: 180W LED 模块; 输出 (当输入电压: 200-240Vac): 36Vdc, 6.66A (恒压恒流), 配套光源: 239.76W LED 模块	—
9	ELG-240-42A	输出 (当输入电压: 100-200Vac): 42Vdc, 4.28A (恒压恒流), 配套光源: 179.76W LED 模块; 输出 (当输入电压: 200-240Vac): 42Vdc, 5.71A (恒压恒流), 配套光源: 239.82W LED 模块	—
10	ELG-240-48A	输出 (当输入电压: 100-200Vac): 48Vdc, 3.75A (恒压恒流), 配套光源: 180W LED 模块; 输出 (当输入电压: 200-240Vac): 48Vdc, 5.0A (恒压恒流), 配套光源: 240W LED 模块	—
11	ELG-240-54A	输出 (当输入电压: 100-200Vac): 54Vdc, 3.34A (恒压恒流), 配套光源: 180.36W LED 模块; 输出 (当输入电压: 200-240Vac): 54Vdc, 4.45A (恒压恒流), 配套光源: 240.3W LED 模块	—
输入: 100-240V~, 50/60Hz, ta: 50°C, tc: 90°C, I类, IP65, SELV,  ,  ,  , 			
备注: 以上型号在正常工作状态下, 实测输入功率均大于25W。			

注: 此附录与证书同时使用时有效;



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

证书编号: 2016011002888991

委托人名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产者(制造商)名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产企业名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园B栋

产品名称和系列、规格、型号

LED模块用交流电子控制装置(LED控制装置,独立式,恒流模式,
安全特低电压,ta:50℃,tc:90℃,I类,IP65,F标记,定温热保
护:110℃)

见附件。100-240V~50/60Hz

产品标准和技术要求

GB19510.14-2009, GB19510.1-2009, GB17743-2007, GB17625.1-
2012

上述产品符合强制性产品认证实施规则
CNCA-C10-01:2014的要求,特发此证。

发证日期: 2016年08月09日 有效期至: 2021年08月09日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1504503



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2016011002888991

NAME AND ADDRESS OF THE APPLICANT

Mean Well (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuan Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME AND ADDRESS OF THE MANUFACTURER

Mean Well (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuan Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME AND ADDRESS OF THE FACTORY

Mean Well (Guangzhou) Electronics Co., Ltd.
B Building, Yuan Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME, MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (Independent,
Constant Current Mode, SELV, ta:50°C, tc:90°C, Class I, IP65, F Mark,
Temperature Declared Thermally Protected: 110°C)
See Appendix. 100-240V~ 50/60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB19510.14-2009, GB19510.1-2009, GB17743-2007, GB17625.1-2012

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C10-01:2014).

Date of issue: Aug. 09, 2016 Date of expiry: Aug. 09, 2021

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnea.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1504503



中国国家强制性产品认证证书

附录:

第 1 页 共 4 页

证书编号: 2016011002888991

纸号: 1504503

序号	产品型号	参数	备注
1	ELG-200-12AB	输出: Max. 12Vdc, 12A (恒流), 配套光源:	可调光
2	ELG-200-12AD2	144W LED 模块 (当输入电压: 100-200Vac);	可调光
3	ELG-200-12ADA	输出: Max. 12Vdc, 16A (恒流), 配套光源:	可调光
		192W LED 模块 (当输入电压: 200-240Vac)	
4	ELG-200-24AB	输出: Max. 24Vdc, 6.25A (恒流), 配套光源:	可调光
5	ELG-200-24AD2	150W LED 模块 (当输入电压: 100-200Vac);	可调光
6	ELG-200-24ADA	输出: Max. 24Vdc, 8.4A (恒流), 配套光源:	可调光
		201.6W LED 模块 (当输入电压: 200-240Vac)	
7	ELG-200-36AB	输出: Max. 36Vdc, 4.16A (恒流), 配套光源:	可调光
8	ELG-200-36AD2	149.76W LED 模块 (当输入电压: 100-200Vac);	可调光
9	ELG-200-36ADA	输出: Max. 36Vdc, 5.55A (恒流), 配套光源:	可调光
		199.8W LED 模块 (当输入电压: 200-240Vac)	

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 4 页

证书编号: 2016011002888991

纸号: 1504503

10	ELG-200-42AB	输出: Max. 42Vdc, 3.57A (恒流), 配套光源:	可调光
11	ELG-200-42AD2	149.94W LED 模块(当输入电压: 100-200Vac); 输出: Max. 42Vdc, 4.76A (恒流), 配套光源:	可调光
12	ELG-200-42ADA	199.9W LED 模块(当输入电压: 200-240Vac)	可调光
13	ELG-200-48AB	输出: Max. 48Vdc, 3.12A (恒流), 配套光源:	可调光
14	ELG-200-48AD2	149.76W LED 模块(当输入电压: 100-200Vac); 输出: Max. 48Vdc, 4.16A (恒流), 配套光源:	可调光
15	ELG-200-48ADA	199.68W LED 模块(当输入电压: 200-240Vac)	可调光
16	ELG-200-54AB	输出: Max. 54Vdc, 2.78A (恒流), 配套光源:	可调光
17	ELG-200-54AD2	150.12W LED 模块(当输入电压: 100-200Vac); 输出: Max. 54Vdc, 3.72A (恒流), 配套光源:	可调光
18	ELG-200-54ADA	200.88W LED 模块(当输入电压: 200-240Vac)	可调光
19	ELG-240-24AB	输出: Max. 24Vdc, 7.5A (恒流), 配套光源:	可调光
20	ELG-240-24AD2	180W LED 模块(当输入电压: 100-200Vac);	可调光

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 3 页 共 4 页

证书编号: 2016011002888991

纸号: 1504503

21	ELG-240-24ADA	输出: Max. 24Vdc, 10A (恒流), 配套光源: 240W LED 模块 (当输入电压: 200-240Vac)	可调光
22	ELG-240-36AB	输出: Max. 36Vdc, 5A (恒流), 配套光源: 180W	可调光
23	ELG-240-36AD2	LED 模块 (当输入电压: 100-200Vac); 输出: Max. 36Vdc, 6.66A (恒流), 配套光源:	可调光
24	ELG-240-36ADA	239.76W LED 模块 (当输入电压: 200-240Vac)	可调光
25	ELG-240-42AB	输出: Max. 42Vdc, 4.28A (恒流), 配套光源:	可调光
26	ELG-240-42AD2	179.76W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 42Vdc, 5.71A (恒流), 配套光源:	可调光
27	ELG-240-42ADA	239.82W LED 模块 (当输入电压: 200-240Vac)	可调光
28	ELG-240-48AB	输出: Max. 48Vdc, 3.75A (恒流), 配套光源:	可调光
29	ELG-240-48AD2	180W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 48Vdc, 5.0A (恒流), 配套光源:	可调光
30	ELG-240-48ADA	240W LED 模块 (当输入电压: 200-240Vac)	可调光

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>






中国国家强制性产品认证证书

附录:

第 4 页 共 4 页

证书编号: 2016011002888991

纸号: 1504503

31	ELG-240-54AB	输出: Max. 54Vdc, 3.34A (恒流), 配套光源:	可调光
32	ELG-240-54AD2	180.36W LED 模块(当输入电压: 100-200Vac); 输出: Max. 54Vdc, 4.45A (恒流), 配套光源:	可调光
33	ELG-240-54ADA	240.3W LED 模块(当输入电压: 200-240Vac)	可调光
输入: 100-240V~, 50/60Hz, ta: 50°C, tc: 90°C, I类, IP65, SELV, 			

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

证书编号: 2016011002889174

委托人名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产者(制造商)名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产企业名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园B栋

产品名称和系列、规格、型号

LED模块用交流电子控制装置(LED控制装置, 独立式, 恒流模式, 安全特低电压, ta: 50℃, tc: 90℃, I类, IP67, F标记, 定温热保护: 110℃)

见附件。100-240V~ 50/60Hz

产品标准和技术要求

GB19510.14-2009, GB19510.1-2009, GB17743-2007, GB17625.1-2012

上述产品符合强制性产品认证实施规则
CNCA-C10-01: 2014的要求, 特发此证。

发证日期: 2016年08月09日 有效期至: 2021年08月09日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1504504



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2016011002889174

NAME AND ADDRESS OF THE APPLICANT

Mean Well (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME AND ADDRESS OF THE MANUFACTURER

Mean Well (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME AND ADDRESS OF THE FACTORY

Mean Well (Guangzhou) Electronics Co., Ltd.
B Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME, MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (Independent,
Constant Current Mode, SELV, ta:50°C, tc:90°C, Class I, IP67, F Mark,
Temperature Declared Thermally Protected: 110°C)
See Appendix. 100-240V~ 50/60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB19510.14-2009, GB19510.1-2009, GB17743-2007, GB17625.1-2012

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C10-01:2014).

Date of issue: Aug.09, 2016 Date of expiry: Aug.09, 2021

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.
This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1504504



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2016011002889174

纸号: 1504504

序号	产品型号	参数	备注
1	ELG-200-12B	输出: Max. 12Vdc, 12A (恒流), 配套光源: 144W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 12Vdc, 16A (恒流), 配套光源: 192W LED 模块 (当输入电压: 200-240Vac)	可调光
2	ELG-200-12D		可调光
3	ELG-200-12D2		可调光
4	ELG-200-12DA		可调光
5	ELG-200-24B	输出: Max. 24Vdc, 6.25A (恒流), 配套光源: 150W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 24Vdc, 8.4A (恒流), 配套光源: 201.6W LED 模块 (当输入电压: 200-240Vac)	可调光
6	ELG-200-24D		可调光
7	ELG-200-24D2		可调光
8	ELG-200-24DA		可调光
9	ELG-200-36B	输出: Max. 36Vdc, 4.16A (恒流), 配套光源: 149.76W LED 模块 (当输入电压: 100-200Vac);	可调光
10	ELG-200-36D		可调光
11	ELG-200-36D2	输出: Max. 36Vdc, 5.55A (恒流), 配套光源: 199.8W LED 模块 (当输入电压: 200-240Vac)	可调光
12	ELG-200-36DA		可调光
13	ELG-200-42B	输出: Max. 42Vdc, 3.57A (恒流), 配套光源: 149.94W LED 模块 (当输入电压: 100-200Vac);	可调光
14	ELG-200-42D		可调光
15	ELG-200-42D2	输出: Max. 42Vdc, 4.76A (恒流), 配套光源: 199.9W LED 模块 (当输入电压: 200-240Vac)	可调光
16	ELG-200-42DA		可调光
17	ELG-200-48B	输出: Max. 48Vdc, 3.12A (恒流), 配套光源: 149.76W LED 模块 (当输入电压: 100-200Vac);	可调光
18	ELG-200-48D		可调光
19	ELG-200-48D2	输出: Max. 48Vdc, 4.16A (恒流), 配套光源: 199.68W LED 模块 (当输入电压: 200-240Vac)	可调光
20	ELG-200-48DA		可调光
21	ELG-200-54B	输出: Max. 54Vdc, 2.78A (恒流), 配套光源: 150.12W LED 模块 (当输入电压: 100-200Vac);	可调光
22	ELG-200-54D		可调光
23	ELG-200-54D2	输出: Max. 54Vdc, 3.72A (恒流), 配套光源: 200.88W LED 模块 (当输入电压: 200-240Vac)	可调光
24	ELG-200-54DA		可调光
25	ELG-240-24B	输出: Max. 24Vdc, 7.5A (恒流), 配套光源: 180W LED 模块 (当输入电	可调光

注: 此附录与证书同时使用时有效;



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2016011002889174

纸号: 1504504

26	ELG-240-24D	压: 100-200Vac);	可调光
27	ELG-240-24D2	输出: Max. 24Vdc, 10A (恒流), 配套光源: 240W LED 模块 (当输入电	可调光
28	ELG-240-24DA	压: 200-240Vac)	可调光
29	ELG-240-36B	输出: Max. 36Vdc, 5A (恒流), 配套光源: 180W LED 模块 (当输入电压:	可调光
30	ELG-240-36D	100-200Vac);	可调光
31	ELG-240-36D2	输出: Max. 36Vdc, 6.66A (恒流), 配套光源: 239.76W LED 模块 (当输	可调光
32	ELG-240-36DA	入电压: 200-240Vac)	可调光
33	ELG-240-42B	输出: Max. 42Vdc, 4.28A (恒流), 配套光源: 179.76W LED 模块 (当输	可调光
34	ELG-240-42D	入电压: 100-200Vac);	可调光
35	ELG-240-42D2	输出: Max. 42Vdc, 5.71A (恒流), 配套光源: 239.82W LED 模块 (当输	可调光
36	ELG-240-42DA	入电压: 200-240Vac)	可调光
37	ELG-240-48B	输出: Max. 48Vdc, 3.75A (恒流), 配套光源: 180W LED 模块 (当输入	可调光
38	ELG-240-48D	电压: 100-200Vac);	可调光
39	ELG-240-48D2	输出: Max. 48Vdc, 5.0A (恒流), 配套光源: 240W LED 模块 (当输入电	可调光
40	ELG-240-48DA	压: 200-240Vac)	可调光
41	ELG-240-54B	输出: Max. 54Vdc, 3.34A (恒流), 配套光源: 180.36W LED 模块 (当输	可调光
42	ELG-240-54D	入电压: 100-200Vac);	可调光
43	ELG-240-54D2	输出: Max. 54Vdc, 4.45A (恒流), 配套光源: 240.3W LED 模块 (当输	可调光
44	ELG-240-54DA	入电压: 200-240Vac)	可调光
输入: 100-240V~, 50/60Hz, ta: 50°C, tc: 90°C, I类, IP67, SELV,			
备注: 以上型号在正常工作状态下, 实测输入功率均大于25W。			

注: 此附录与证书同时使用时有效;



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

证书编号: 2016011002884437

委托人名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产者(制造商)名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产企业名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园B栋

产品名称和系列、规格、型号

LED模块用交流电子控制装置(LED控制装置, 独立式, 恒压/恒流模式, 安全特低电压, ta: 50℃, tc: 90℃, I类, IP67, F标记, 定温热保护: 110℃)

见附件。100-240V~ 50/60Hz.

产品标准和技术要求

GB19510.14-2009, GB19510.1-2009, GB17743-2007, GB17625.1-2012

上述产品符合强制性产品认证实施规则
CNCA-C10-01: 2014的要求, 特发此证。

发证日期: 2016年07月26日

有效期至: 2021年07月26日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1361019



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2016011002884437

NAME AND ADDRESS OF THE APPLICANT

Mean Well (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME AND ADDRESS OF THE MANUFACTURER

Mean Well (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME AND ADDRESS OF THE FACTORY

Mean Well (Guangzhou) Electronics Co., Ltd.
B Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME, MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (Independent,
Constant Voltage/Constant Current Mode, SELV, ta:50°C, tc:90°C, Class
I, IP67, F Mark, Temperature Declared Thermally Protected: 110°C)
See Appendix. 100-240V~ 50/60Hz.

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB19510.14-2009, GB19510.1-2009, GB17743-2007, GB17625.1-2012

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C10-01:2014).

Date of issue: Jul.26,2016 Date of expiry: Jul.26,2021

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1361019



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2016011002884437

纸号: 1361019

序号	产品型号	参数	备注
1	ELG-200-12	输出 (当输入电压: 100-200Vac): 12Vdc, 12A (恒压恒流), 配套光源: 144W LED 模块; 输出 (当输入电压: 200-240Vac): 12Vdc, 16A (恒压恒流), 配套光源: 192W LED 模块	—
2	ELG-200-24	输出 (当输入电压: 100-200Vac): 24Vdc, 6.25A (恒压恒流), 配套光源: 150W LED 模块; 输出 (当输入电压: 200-240Vac): 24Vdc, 8.4A (恒压恒流), 配套光源: 201.6W LED 模块	—
3	ELG-200-36	输出 (当输入电压: 100-200Vac): 36Vdc, 4.16A (恒压恒流), 配套光源: 149.76W LED 模块; 输出 (当输入电压: 200-240Vac): 36Vdc, 5.55A (恒压恒流), 配套光源: 199.8W LED 模块	—
4	ELG-200-42	输出 (当输入电压: 100-200Vac): 42Vdc, 3.57A (恒压恒流), 配套光源: 149.94W LED 模块; 输出 (当输入电压: 200-240Vac): 42Vdc, 4.76A (恒压恒流), 配套光源: 199.9W LED 模块	—
5	ELG-200-48	输出 (当输入电压: 100-200Vac): 48Vdc, 3.12A (恒压恒流), 配套光源: 149.76W LED 模块; 输出 (当输入电压: 200-240Vac): 48Vdc, 4.16A (恒压恒流), 配套光源: 199.68W LED 模块	—
6	ELG-200-54	输出 (当输入电压: 100-200Vac): 54Vdc, 2.78A (恒压恒流), 配套光源: 150.12W LED 模块; 输出 (当输入电压: 200-240Vac): 54Vdc, 3.72A (恒压恒流), 配套光源: 200.88W LED 模块	—

注: 此附录与证书同时使用时有效;



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2016011002884437

纸号: 1361019

7	ELG-240-24	输出 (当输入电压: 100-200Vac): 24Vdc, 7.5A (恒压恒流), 配套光源: 180W LED 模块; 输出 (当输入电压: 200-240Vac): 24Vdc, 10A (恒压恒流), 配套光源: 240W LED 模块	—
8	ELG-240-36	输出 (当输入电压: 100-200Vac): 36Vdc, 5A (恒压恒流), 配套光源: 180W LED 模块; 输出 (当输入电压: 200-240Vac): 36Vdc, 6.66A (恒压恒流), 配套光源: 239.76W LED 模块	—
9	ELG-240-42	输出 (当输入电压: 100-200Vac): 42Vdc, 4.28A (恒压恒流), 配套光源: 179.76W LED 模块; 输出 (当输入电压: 200-240Vac): 42Vdc, 5.71A (恒压恒流), 配套光源: 239.82W LED 模块	—
10	ELG-240-48	输出 (当输入电压: 100-200Vac): 48Vdc, 3.75A (恒压恒流), 配套光源: 180W LED 模块; 输出 (当输入电压: 200-240Vac): 48Vdc, 5.0A (恒压恒流), 配套光源: 240W LED 模块	—
11	ELG-240-54	输出 (当输入电压: 100-200Vac): 54Vdc, 3.34A (恒压恒流), 配套光源: 180.36W LED 模块; 输出 (当输入电压: 200-240Vac): 54Vdc, 4.45A (恒压恒流), 配套光源: 240.3W LED 模块	—
输入: 100-240V~, 50/60Hz, ta: 50°C, tc: 90°C, I类, IP67, SELV,			
备注: 以上型号在正常工作状态下, 实测输入功率均大于25W。			

注: 此附录与证书同时使用时有效;



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>

