

# IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Independent LED driver

Name and address of the applicant

MEAN WELL Enterprises Co., Ltd.  
No.28, Wuquan 3rd Rd., Wugu District, New Taipei City 24891  
Taiwan

Name and address of the manufacturer

MEAN WELL Enterprises Co., Ltd.  
No.28, Wuquan 3rd Rd., Wugu District, New Taipei City 24891  
Taiwan

Name and address of the factory

Note: When more than one factory, please report on page 2

☒ Additional information on page 2

MEAN WELL (GUANGZHOU) Electronics Co. Ltd. Huadu Branch  
No.11 Jingu South Road, Huadong Town, Huadu District, Guangzhou 510890, Guangdong  
China

Ratings and principal characteristics

Class I, ta: 40 °C, tc: 85 °C, λ: 0,95, IP67, NON-SELV Independent  
controlgears, non-inherently short-circuit proof, 110 °C thermal protection,  
Other information refer to General product information for details of test  
report.

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

ELGC-300-L-Y  
(Y=blank, A, B, AB, DA, ADA, D2 or AD2)

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

This CB Test Certificate is an addition to CB NL-53992 with Test Report Number 4345289.51 dated  
2018-08-17 due to added one new factory and updated standard.

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

National differences:

EU Group Differences, EU Special National Conditions, AU, NZ  
4357294.50

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## Additional factory

MEAN WELL Enterprises Co., Ltd.

No.28, Wuquan 3rd Rd., Wugu District, New Taipei City 24891

Taiwan

Suzhou MEAN WELL Technology Co., Ltd.

No. 77, Jian-min Road, Dong-qiao, Pan-yang Ind. Park, Huang-dai Town,  
Xiang-cheng District, Suzhou 215152, Jiangsu

China

YONGDEN TECHNOLOGY CORPORATION

345 MacArthur HighWay Tabang 3015, Guiguinto, Bulacan

Philippines

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.

Meander 1051, NL-6825 MJ Arnhem, Netherlands



# IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Independent LED driver

Name and address of the applicant

MEAN WELL Enterprises Co., Ltd.  
No.28, Wuquan 3rd Rd., Wugu District, New Taipei City 24891  
Taiwan

Name and address of the manufacturer

MEAN WELL Enterprises Co., Ltd.  
No.28, Wuquan 3rd Rd., Wugu District, New Taipei City 24891  
Taiwan

Name and address of the factory

Note: When more than one factory, please report on page 2

☒ [Additional information on page 2](#)

MEAN WELL (GUANGZHOU) Electronics Co., Ltd. Huadu Branch  
No.11 Jingu South Road, Huadong Town, Huadu District, Guangzhou 510890, Guangdong  
China

Ratings and principal characteristics

Class I, ta: 40 °C, tc: 85 °C, λ: 0,95, IP67, non-inherently short-circuit  
proof,  
110 °C thermal protection.  
ELGC-300-X-Y, ELG-300-24Y, ELG-300-12, ELG-300-12A: SELV Independent  
controlgears;  
ELGC-300-L-Y: NON-SELV Independent controlgears.  
Other information refers to General product information for details.

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

ELGC-300-X-Y, ELG-300-24Y, ELG-300-12, ELG-300-12A, ELGC-300-L-Y  
(X=H or M, Y=blank, A, B, AB, DA, ADA, D2 or AD2)

Additional information (if necessary may also be reported on page 2)

☒ [Additional information on page 2](#)

This CB Test Certificate is an addition to CB NL-53992 with Test Report Number  
4345289.50+4345289.51 dated 2018-08-17 due to addition of new models and factory, update of  
Australia (AU) / New Zealand (NZ) deviation.

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

National differences:

EU Group Differences, EU Special National Conditions, AU, NZ  
4351629.50+4345289.51

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands




IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## Additional factory

MEAN WELL Enterprises Co., Ltd.

No.28, Wuquan 3rd Rd., Wugu District, New Taipei City 24891

Taiwan

SuZhou MEAN WELL Technology Co., Ltd.

No. 77, Jian-min Road, Dong-qiao, Pan-yang Ind. Park, Huang-dai Town,  
Xiang-cheng District, Suzhou 215152, Jiangsu

China

YONGDEN TECHNOLOGY CORPORATION

345 MacArthur HighWay Tabang, Guiguinto, Bulacan

Philippines

## Additional information

The factory "YONGDEN TECHNOLOGY CORPORATION" is for SELV Independent controlgears(ELGC-300-X-Y, ELG-300-24Y, ELG-300-12, ELG-300-12A.)

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.

Meander 1051, NL-6825 MJ Arnhem, Netherlands



# IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Independent LED driver

Name and address of the applicant

MEAN WELL Enterprises Co., Ltd.  
No.28, Wuquan 3rd Road, Wugu Dist, New Taipei City 248  
Taiwan

Name and address of the manufacturer

MEAN WELL Enterprises Co., Ltd.  
No.28, Wuquan 3rd Road, Wugu Dist, New Taipei City 248  
Taiwan

Name and address of the factory

Note: When more than one factory, please report on page 2

☒ Additional information on page 2

MEAN WELL (Guangzhou) Electronics Co. Ltd. Huadu Branch  
No.11 Jingu South Road, Huadong Town, Huadu District, 510890 Guangzhou, Guangdong  
China

Ratings and principal characteristics

Class I, ta: 40 °C, tc: 85 °C, λ: 0,95, IP67, non-inherently short-circuit  
proof, 110 °C thermal protection;  
ELGC-300-X-Y, ELG-300-24Y: SELV Independent controlgears;  
ELGC-300-L-Y: NON-SELV Independent controlgears  
(Details refer to General product information of test report)

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

ELGC-300-X-Y, ELG-300-24Y (X=H or M), ELGC-300-L-Y  
(Y=blank, A, B, AB, DA, ADA, D2 or AD2)

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

National differences:

EU Group Differences, EU Special National Conditions, AU, NZ

As shown in the Test Report Ref. No. which forms part of this Certificate

4345289.50 + 4345289.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands


Date: 2018-08-17

Signature: Miranda Zhou



page 1 of 2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## Additional factory

MEAN WELL Enterprises Co., Ltd.  
No.28, Wuquan 3rd, Wugu Dist, New Taipei City 248  
Taiwan

Suzhou MEAN WELL Technology Co., Ltd.  
No. 77, Jian-min Road, Dong-qiao, Pan-yang Ind. Park, Huang-dai Town,  
Xiang-cheng Dist, Suzhou, 215152 Jiangsu  
China

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2018-08-17

Signature: Miranda Zhou



page 2 of 2