



中国国家强制性产品认证证书

证书编号: 2016011002845050

委托人名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产者(制造商)名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产企业名称、地址

明纬(广州)电子有限公司花都分公司
广州市花都区花东镇金谷南路11号

产品名称和系列、规格、型号

LED模块用交流电子控制装置(LED控制装置,整体式,恒流模式,
安全特低电压)

见附件: 100-240V~ 50/60Hz.

产品标准和技术要求

GB19510.14-2009, GB19510.1-2009, GB17743-2007, GB17625.1-
2012

上述产品符合强制性产品认证实施规则
CNCA-C10-01:2014的要求,特发此证。

发证日期: 2016年12月27日

有效期至: 2021年03月01日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书,证书首次颁发日期: 2016年03月01日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1597718



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2016011002845050

NAME AND ADDRESS OF THE APPLICANT

MEAN WELL (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME AND ADDRESS OF THE MANUFACTURER

MEAN WELL (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME AND ADDRESS OF THE FACTORY

MEAN WELL (GUANGZHOU) ELECTRONICS CO., LTD HUADU BRANCH
No.11 Jingu South Road, Huadong Town, Huadu District, Guangzhou, China

NAME, MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (Power LED
Driver, Integral, Constant Current Mode, SELV)
See Appendix; 100-240V~ 50/60Hz.

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB19510.14-2009, GB19510.1-2009, GB17743-2007, GB17625.1-2012

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C10-01:2014).

Date of issue: Dec.27, 2016 Date of expiry: Mar.01, 2021

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

Date of original certification: Mar.01, 2016

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1597718



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2016011002845050

纸号: 1597718

序号	产品型号	参数
1	HBG-100P-36A	输出: Max. 37Vdc, 2.7A (恒流), 配套光源: Max. 97.2W LED 模块
2	HBG-100P-48A	输出: Max. 49Vdc, 2.0A (恒流), 配套光源: Max. 96W LED 模块
3	HBG-100P-60A	输出: Max. 62Vdc, 1.6A (恒流), 配套光源: Max. 96W LED 模块
输入: 100-240V~, 50/60Hz, SELV, 整体式 LED 控制装置		
备注: 以上型号在正常工作状态下, 实测输入功率均大于25W;		

注: 此附录与证书同时使用时有效;



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

证书编号: 2016011002845047

委托人名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产者(制造商)名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产企业名称、地址

明纬(广州)电子有限公司花都分公司
广州市花都区花东镇金谷南路11号

产品名称和系列、规格、型号

LED模块用交流电子控制装置(LED控制装置,整体式,可调光,恒流模式,安全特低电压)
见附件:100-240V~50/60Hz.

产品标准和技术要求

GB19510.14-2009, GB19510.1-2009, GB17743-2007, GB17625.1-2012

上述产品符合强制性产品认证实施规则
CNCA-C10-01:2014的要求,特发此证。

发证日期:2016年12月27日

有效期至:2021年03月01日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书,证书首次颁发日期:2016年03月01日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1597720



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2016011002845047

NAME AND ADDRESS OF THE APPLICANT

MEAN WELL (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME AND ADDRESS OF THE MANUFACTURER

MEAN WELL (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME AND ADDRESS OF THE FACTORY

MEAN WELL (GUANGZHOU) ELECTRONICS CO., LTD HUADU BRANCH
No.11 Jingu South Road, Huadong Town, Huadu District, Guangzhou, China

NAME, MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (Power LED
Driver, Integral, Dimmable, Constant Current Mode, SELV)
See Appendix; 100-240V~ 50/60Hz.

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB19510.14-2009, GB19510.1-2009, GB17743-2007, GB17625.1-2012

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C10-01:2014).

Date of issue: Dec.27,2016 Date of expiry: Mar.01,2021

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

Date of original certification: Mar.01,2016

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1597720



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2016011002845047

纸号: 1597720

序号	产品型号	参数
1	HBG-100P-36B	输出: Max. 37Vdc, 2.7A (恒流), 配套光源: Max. 97.2W LED 模块
2	HBG-100P-48B	输出: Max. 49Vdc, 2.0A (恒流), 配套光源: Max. 96W LED 模块
3	HBG-100P-60B	输出: Max. 62Vdc, 1.6A (恒流), 配套光源: Max. 96W LED 模块
输入: 100-240V~, 50/60Hz, SELV, 整体式 LED 控制装置, 调光方式: 0-10V \Rightarrow 电压信号输入调光、10V \Rightarrow PWM 信号调光、外接电阻调光。		
备注: 以上型号在正常工作状态下, 实测输入功率均大于25W;		

注: 此附录与证书同时使用时有效;



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

