



中国国家强制性产品认证证书

证书编号：2018011002043765

委托人名称、地址

明纬（广州）电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产者（制造商）名称、地址

明纬企业股份有限公司
台湾新北市五股区五权三路28号

生产企业名称、地址

明纬（广州）电子有限公司花都分公司
广州市花都区花东镇金谷南路11号

产品名称和系列、规格、型号

LED 模块用交流电子控制装置（LED 控制装置，部分型号控制端口调光，内装式，恒流模式，安全特低电压， $t_a:50^{\circ}\text{C}$ ， $t_c:80^{\circ}\text{C}$ ，定温热保护： 110°C ）

见附件。200-240V~50/60Hz

产品标准和技术要求

GB17625.1-2012;GB/T17743-2017;GB19510.1-2009;GB19510.14-2009

上述产品符合强制性产品认证实施规则 CNCA-C10-01:2014 的要求，特发此证。

发证日期：2019年11月27日 有效期至：2023年01月26日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2018年01月26日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：

陆梅



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2018011002043765

NAME AND ADDRESS OF THE APPLICANT

MEAN WELL (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District, Guangzhou, China

NAME AND ADDRESS OF THE MANUFACTURER

MEAN WELL Enterprises Co.,Ltd.
No. 28, Wuquan 3rd Road, Wugu District, New Taipei City, Taiwan

NAME AND ADDRESS OF THE FACTORY

MEAN WELL (Guangzhou) Electronics Co., Ltd Huadu Branch
No.11 Jingu South Road, Huadong Town, Huadu District, Guangzhou, China

PRODUCT NAME, MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (Controlled Port Dimming for some type, Built-in, Constant Current Mode, SELV, $t_a:50^{\circ}\text{C}$, $t_c:80^{\circ}\text{C}$,
Temperature Declared Thermally Protected: 110°C)

See Appendix. 200-240V~50/60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB17625.1-2012;GB/T17743-2017;GB19510.1-2009;GB19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C10-01:2014).

Valid from: Nov.27,2019

Valid until: Jan.26,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Jan.26,2018

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

变更结论 Modification Approval

证书编号 Certificate No. : 2018011002043765

申请编号 Application No. : A2019CCC1002-3326680

申请人(委托人) Applicant: 明纬(广州)电子有限公司 / MEAN WELL (Guangzhou) Electronics Co., Ltd.

证书编号 Certificate No.(变更前 Original): 2018011002043765

变更产品名称: LED 模块用交流电子控制装置 (LED 控制装置, 部分型号控制端口调光, 内装式, 恒流模式, 安全特低电压, ta:50°C, tc:80°C, 定温热保护: 110°C)

Name of Product Modified: A.C. Supplied Electronic Controlgear For LED Modules (Controlled Port Dimming for some type, Built-in, Constant Current Mode, SELV, ta:50°C, tc:80°C,, Temperature Declared Thermally Protected: 110°C)

变更情况 Situation of Modification (见下表 See table below) :

序号	项目 Item	变更前 Original	变更后 Present
1	产品认证所依据的国家标准、技术规则或者认证实施细则发生了变化	GB/T17743-2007	GB/T17743-2017
2	在证书上增加同种产品其它型号	见检测报告编号: C-00401-T1803QM-01544	见检测报告编号: C-00401-T1910QM-05962
3	LDC-55B 调光类型变更	见检测报告编号: C-00401-T1803QM-01544	见检测报告编号: C-00401-T1910QM-05962
4	关键件变更	见检测报告编号: C-00401-T1803QM-01544	见检测报告编号: C-00401-T1910QM-05962

现批准以上变更。

Above Modification is approved. The present will replace the original.

批准日期 (Date) : 2019 年 11 月 27 日

第 1 页 / 共 1 页



主任: 陆梅



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号：2018011002043765

纸 号：2465347

型号	恒流输出			备注
	输出电流 (A)	输出电压 (Vdc)	最大输出电 压 (Vdc)	
LDC-55	0.5-1.6	27-56	60	不可调光
LDC-55B				可调光
LDC-55DA				可调光
LDC-55DA2				可调光

调光方式说明：

- 1、LDC-55B 型调光方式：外接电阻调光；
- 2、LDC-55DA 型调光方式：DALI 功能、Push dimming 功能调光；
- 3、LDC-55DA2 型调光方式：DALI 功能、Push dimming 功能调光。

LDC-55DA2 与 LDC-55DA 都有 DALI 调光，只是 DALI 版本差异：LDC-55DA2 是 DALI 2.0 版本，LDC-55DA 是 DALI 1.0 版本。

输入：200-240V~ 50/60Hz, 0.35A

注：此附录与证书同时使用时有效。



主 任：

陆梅



中国质量认证中心